

New Venting Requirements for Canadian Installations

P/N# 240006277, Rev. 1.0 [11/06]

SUPPLEMENTAL INSTRUCTIONS

IMPORTANT

These Instructions are in addition to any existing Combustion Air and Vent Pipe installation instructions in the boiler installation manual, the boilers user's manual or any other existing supplemental instructions or addendum. The information in this Supplemental Instructions is to be used in place of that in the following Installation Manuals: 240006103D rev 1.1, 240006103U rev 1.1, 240006103B rev 1.1, 240006103BF rev 1.0, 14683301 rev 3.1, 1305011 rev2.1, 240004826D rev 1.3, 240004826U rev 1.3, 240004826BF rev 1.3, 240004826B rev 1.3, 1305015 rev 2.1, 1305016 rev 2.1.

CAUTION

Please read these instructions carefully before installing vent pipe.

In Canada construct all combustion air and vent pipes for this unit of CSA or ULC certified schedule-40 CPVC, schedule-40 PVC, PVC-DWV or ABS-DWV pipe and pipe cement. For Canadian installation all plastic venting material must be listed to ULC S636. SDR pipe is NOT approved in Canada.
